

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7165-1076:119

Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Kidde-Fenwal, Inc., 400 Main Street, Ashland MA 01721-2150
Contact: Terrill Garland (508) 881-2000

DESIGN: Models "2320" and "Scorpio" local fire alarm control units. Noncoded, automatic, manual, water flow, and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and operational considerations.

<u>Model</u>	<u>Part Number</u>	<u>Description</u>
2320	30-232000-101	Control Unit w/120VAC Transformer
2320	30-232000-103	Control Unit w/240VAC Transformer
2320*	30-232000-011	Upgrade/Retrofit Kit
Scorpio*	84-232000-012	Upgrade/Retrofit Kit
Scorpio	84-232000-102	Control Unit w/120VAC Transformer
Scorpio	84-232000-104	Control Unit w/240VAC Transformer
	06-119520-020	12 VDC, 1.2 Ah Lead Acid Battery

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 07-16-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager